



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098
An Environmental Laboratory approved by MoEFCC.
vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.
402 Purushottam Plaza, Baner Road, Pune- 411 045
Tel. 020-46781028 E-mail : kleanlab@klean.org Website : www.klean.org



TEST REPORT					
Test Report No	2022/05/STP R/1312	Date	20.05.2022		
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Raw Sewage	Plastic Bottle	Lab	500 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
11.05.2022	12.05.2022	12.05.2022	20.05.2022		
Sampling Procedure	As per KLRPL/QSP/22				
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.50
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	72
3	C.O.D.	APHA 5220 C 2017	mg/L	--	363
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	118
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 1)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
Page 1/1		V.W. Kale			



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH42009PTC195698

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 837 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2022/05/STP T/1313	Date	20.05.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
11.05.2022	12.05.2022	12.05.2022	20.05.2022

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.48
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 1)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	29
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	5
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 1)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.




 KLEAN LABORATORIES AND RESEARCH (P) LTD. MUMBAI
 V.W. Kale



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098
 An Environmental Laboratory approved by MoEFCC.
 vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.
 402 Purushottam Plaza, Baner Road, Pune- 411 045.
 Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT					
Test Report No	2022/06/STP R/1637	Date	15.06.2022		
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Raw Sewage	Plastic Bottle	Lab	500 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
07.06.2022	08.06.2022	08.06.2022	15.06.2022		
Sampling Procedure	As per KLRPL/QSP/22				
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.90
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	30
3	C.O.D.	APHA 5220 C 2017	mg/L	--	422
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	148
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 1)
End of test report					

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Sanjay

Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098
An Environmental Laboratory approved by MoEFCC.
vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.
402 Purushottam Plaza, Baner Road, Pune- 411 045.
Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2022/06/STP T/1638	Date	15.06.2022		
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Treated Sewage	Plastic Bottle	Lab	1000 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
07.06.2022	08.06.2022	08.06.2022	15.06.2022		
As per KLRPI/QSP/22					
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.60
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 1)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	26
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	4
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/l.	--	BDL(MDL< 1)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.
This report cannot be reproduced in parts and pertains to the sample(s) as received.
Hologram Mandatory.



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Our bill for operation of Sewage Treatment Plant of Rs. 21,159/- for the month of June -2022 is enclosed for your certification and necessary payment.

Thanking You,

Yours Faithfully,

FOR KLEAN LABORATORIES AND RESEARCH PVT. LTD.




Authorized Signatory

- Encl.: 1) Analysis Reports of Raw and Treated sewage samples for the month **June-2022**
2) Bill for O & M of Sewage Treatment Plant for the month of **June-2022**



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN: U73100MH2000PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Barar Road, Pune- 411 045.

Tel: 020-46781028 E-mail: kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2022/07/STPR/2049	Date	19.07.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated: 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Raw Sewage	Plastic Bottle	Lab	500 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
11.07.2022	12.07.2022	12.07.2022	19.07.2022


Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.02
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	75
3	C.O.D.	APHA 5220 C 2017	mg/L	--	323
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	100
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 1)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Sanjay



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2022/07/STPT/2050	Date	19.07.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
11.07.2022	12.07.2022	12.07.2022	19.07.2022

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.10
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL < 1)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	25
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	4
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 1)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Sanjay

Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Ref. No. 2208/Vidyalankar/54

05th August, 2022

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF JULY-2022.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for July -2022.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on 11/07/2022 and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	7.02	7.10	6.5 – 8.5
2	Suspended Solids	75	BDL(MDL<1)	< 100
3	C.O.D.	323	25	< 250
4	3 Day B.O.D. @ 27°C	100	4	< 100
5	Oil & Grease	BDL(MDL<1)	BDL(MDL<1)	< 10

1) Activities undertaken during the month of July -2022.

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Bach wash to sand and carbon filters.

B) Periodic Activities:

- Sludge removal and dewatering.
- Settling tank cleaning.
- Treated water tank cleaning.
- Water samples collection for analysis.



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC19509B

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Banner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT					
Test Report No	2022/08/STPR/2117		Date	13.08.2022	
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Raw Sewage	Plastic Bottle	Lab	500 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
05.08.2022	06.08.2022	06.08.2022	13.08.2022		
Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.08
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	20
3	C.O.D.	APHA 5220 C 2017	mg/L	--	169
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	64
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 5)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
Page 1/1		Authorised by (Sanjay Mardikar G M)			



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sn. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2022/08/STPT/2118	Date	13.08.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
05.08.2022	06.08.2022	06.08.2022	13.08.2022

Sampling Procedure As per KLRPL/QSP/22


Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.74
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	2
3	C.O.D.	APHA 5220 C 2017	mg/L	--	20
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	4
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC,
vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.
402 Purushottam Plaza, Baner Road, Pune- 411 045.
Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Ref. No. 2209/Vidyalankar/056

08th September, 2022

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF AUGUST-2022.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for August -2022.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on **05/08/2022** and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	7.08	7.74	6.5 – 8.5
2	Suspended Solids	20	2	< 100
3	C.O.D.	169	20	< 250
4	3 Day B.O.D. @ 27 ^o C	64	4	< 100
5	Oil & Grease	BDL(MDL<5)	BDL(MDL<5)	< 10


1) **Activities undertaken during the month of August -2022.**

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Back wash to sand and carbon filters.

B) Periodic Activities:

- Sludge removal and dewatering.
- Settling tank cleaning.
- Treated water tank cleaning.
- Water samples collection for analysis.

**KLEAN LABORATORIES AND RESEARCH (P) LTD.**

CIN - U73100MH2009PTC19509B

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sn No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

**TEST REPORT**

Test Report No	2022/09/STPR/2444	Date	17.09.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Raw Sewage	Plastic Bottle	Lab	500 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
08.09.2022	10.09.2022	10.09.2022	17.09.2022

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.93
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	18
3	C.O.D.	APHA 5220 C 2017	mg/L	--	103
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	42
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Page 1/1

Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098
An Environmental Laboratory approved by MoEFCC.
vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.
402 Purushottam Plaza, Baner Road, Pune- 411 045.
Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT			
Test Report No	2022/09/STPT/2445	Date	17.09.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS			
Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
08.09.2022	10.09.2022	10.09.2022	17.09.2022


Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.57
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 5)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	16
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	3
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

*An Environmental Laboratory approved by MoEFCC,
vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.*

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Our bill for operation of Sewage Treatment Plant of **Rs. 17,534/-** for the month of **September-2022** is enclosed for your certification and necessary payment.

Thanking You,

Yours Faithfully,

FOR KLEAN LABORATORIES AND RESEARCH PVT. LTD.



Authorized Signatory

- Encl.: 1) Analysis Reports of Raw and Treated sewage samples for the month **September-2022**
2) Bill for O & M of Sewage Treatment Plant for the month of **September-2022**

**KLEAN LABORATORIES AND RESEARCH (P) LTD.**

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Ref. No. 2211/Vidyalankar/085

04th November, 2022

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).**SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF OCTOBER-2022.**

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **OCTOBER-2022**.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on **10/10/2022** and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	6.92	7.69	6.5 – 8.5
2	Suspended Solids	26	BDL(MDL<5)	< 100
3	C.O.D.	198	24	< 250
4	3 Day B.O.D. @ 27°C	76	6	< 100
5	Oil & Grease	BDL(MDL<5)	BDL(MDL<5)	< 10

1) Activities undertaken during the month of October -2022.**A) Daily Activities:**

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Back wash to sand and carbon filters.

B) Periodic Activities:

- Sludge removal and dewatering.
- Settling tank cleaning.
- Treated water tank cleaning.
- Water samples collection for analysis.



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT					
Test Report No	2022/10/STPT/2734		Date	18.10.2022	
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by		Quantity	
Treated Sewage	Plastic Bottle	Lab		1000 ml	
Sample collection Date	Sample receipt Date	Analysis start Date		Analysis complete Date	
10.10.2022	11.10.2022	11.10.2022		18.10.2022	
Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.69
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 5)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	24
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	6
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
Page 1/1		Authorised by (Sanjay Mardikar G M)			



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.


Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Our bill for operation of Sewage Treatment Plant of Rs. 17,936/- for the month of **October-2022** is enclosed for your certification and necessary payment.

Thanking You,

Yours Faithfully,

FOR KLEAN LABORATORIES AND RESEARCH PVT. LTD.


Authorized Signatory



Encl.: 1) Analysis Reports of Raw and Treated sewage samples for the month **October-2022**
2) Bill for O & M of Sewage Treatment Plant for the month of **October-2022**



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TC-5512

TEST REPORT

Test Report No	2022/11/STPR/2852	Date	12.11.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Raw Sewage	Plastic Bottle	Lab	500 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
04.11.2022	05.11.2022	05.11.2022	12.11.2022

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	8.05
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	44
3	C.O.D.	APHA 5220 C 2017	mg/L	--	256
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	92
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)


End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.




Authorised by (Sanjay Marudkar G M)





KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2022/11/STPT/2853	Date	12.11.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
04.11.2022	05.11.2022	05.11.2022	12.11.2022

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.43
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 5)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	31
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	5
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.


Hologram Mandatory.



Sanjay



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website : www.klean.org

Ref. No. 2212/Vidyalankar/91

08th December, 2022

M/S. VIDYALANKAR DNYANPEETH TRUST

Vidyalankar Education Complex,

Vidyalankar College Marg, Sangam Nagar,

Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF NOVEMBER-2022.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **November-2022**.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on **04/11/2022** and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	8.05	7.43	6.5 – 8.5
2	Suspended Solids	44	BDL(MDL<5)	< 100
3	C.O.D.	256	31	< 250
4	3 Day B.O.D. @ 27°C	92	5	< 100
5	Oil & Grease	BDL(MDL<5)	BDL(MDL<5)	< 10

1) **Activities undertaken during the month of November -2022.**

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Back wash to sand and carbon filters.

B) Periodic Activities:

- Sludge removal and dewatering.
- Settling tank cleaning.
- Treated water tank cleaning.
- Water samples collection for analysis.



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Ref. No. 2301/Vidyalankar/99

04th January, 2023

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF DECEMBER-2022.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **December-2022**.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on 09/12/2022 and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	6.91	6.93	6.5 – 8.5
2	Suspended Solids	102	BDL(MDL<5)	< 100
3	C.O.D.	998	28	< 250
4	3 Day B.O.D. @ 27°C	348	5	< 100
5	Oil & Grease	BDL(MDL<5)	BDL(MDL<5)	< 10

1) Activities undertaken during the month of December -2022.

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Bach wash to sand and carbon filters.

B) Periodic Activities:

- Sludge removal and dewatering.
- Settling tank cleaning.
- Treated water tank cleaning.
- Water samples collection for analysis.



TEST REPORT					
Test Report No	2022/12/STPR/3249		Date	17.12.2022	
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by		Quantity	
Raw Sewage	Plastic Bottle	Lab		500 ml	
Sample collection Date	Sample receipt Date	Analysis start Date		Analysis complete Date	
09.12.2022	10.12.2022	10.12.2022		17.12.2022	
Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.91
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	102
3	C.O.D.	APHA 5220 C 2017	mg/L	--	998
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	348
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 5)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
		 Authorised by (Sanjay Mardikar G M)			



TEST REPORT			
Test Report No	2022/12/STPT/3250	Date	17.12.2022
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
09.12.2022	10.12.2022	10.12.2022	17.12.2022

Sampling Procedure

As per KLRPL/QSP/22


Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.93
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 5)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	28
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	5
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report


BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Sanjay



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

TEST REPORT					
Test Report No	2023/01/STPR/167	Date	12.01.2023		
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Raw Sewage	Plastic Bottle	Lab	500 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
04.01.2023	05.01.2023	05.01.2023	12.01.2023		
Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.86
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	88
3	C.O.D.	APHA 5220 C 2017	mg/L	--	846
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	296
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
Page 1/1		Authorised by (Sanjay Mardikar G M)			





KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

TEST REPORT

Test Report No	2023/01/STPT/168	Date	12.01.2023
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
04.01.2023	05.01.2023	05.01.2023	12.01.2023
Sampling Procedure	As per KLRPL/QSP/22		


Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.96
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 5)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	32
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	6
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Sanjay



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Ref. No. 2302/Vidyalankar/101

08th February, 2023

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF JANUARY-2023.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **January-2023**.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on 04/01/2023 and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	6.86	6.96	6.5 – 8.5
2	Suspended Solids	88	BDL(MDL<5)	< 100
3	C.O.D.	846	32	< 250
4	3 Day B.O.D. @ 27°C	296	6	< 100
5	Oil & Grease	BDL(MDL<5)	BDL(MDL<5)	< 10

1) **Activities undertaken during the month of January-2023.**

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Back wash to sand and carbon filters.

**KLEAN LABORATORIES AND RESEARCH (P) LTD.**

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

402 Purushottam Plaza, Baner Road, Pune- 411045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT					
Test Report No	2023/06/STPR/1274	Date	27.06.2023		
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Raw Sewage	Plastic Bottle	Lab	500 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
21.06.2023	22.06.2023	22.06.2023	27.06.2023		
Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.10
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	70
3	C.O.D.	APHA 5220 C 2017	mg/L	--	298
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	98
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 1)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
					
Page 1/1	Authorised by (Sanjay Mardikar G M)				



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

402 Purushottam Plaza, Baner Road, Pune - 411045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2023/06/STPT/1275	Date	27.06.2023
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
21.06.2023	22.06.2023	22.06.2023	27.06.2023

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	8.44
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	6
3	C.O.D.	APHA 5220 C 2017	mg/L	--	45
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	8
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 1)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Sanjay

Authorised by (Sanjay Mardikar G M)






KLEAN LABORATORIES AND RESEARCH (P) LTD.
CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

402 Purushottam Plaza, Baner Road, Pune - 411045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT					
Test Report No	2023/05/STPR/1055		Date	23.05.2023	
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Raw Sewage	Plastic Bottle	Lab	500 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
15.05.2023	16.05.2023	16.05.2023	23.05.2023		
Sampling Procedure	As per KLRPL/QSP/22				
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.34
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	50
3	C.O.D.	APHA 5220 C 2017	mg/L	--	270
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	88
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 1)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
					
Page 1/1		Authorised by (Sanjay Mardikar G M)			



KLEAN LABORATORIES AND RESEARCH (P) LTD.




CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

402 Purushottam Plaza, Baner Road, Pune- 411045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT					
Test Report No	2023/04/STPT/1056	Date	23.05.2023		
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Treated Sewage	Plastic Bottle	Lab	1000 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
15.05.2023	16.05.2023	16.05.2023	23.05.2023		
Sampling Procedure		As per KLRPL/QSP/22			
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.02
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 1)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	48
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	8
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 1)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
					
Page 1/1		Authorised by (Sanjay Mardikar G M)			



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC,

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail: kleanlab@klean.org Website: www.klean.org

Ref. No. 2306/Vidyalankar/006

17th June, 2023

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF MAY-2023.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **May-2023**.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on 15/05/2023 and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	7.34	7.02	6.5 – 8.5
2	Suspended Solids	50	BDL(MDL<1)	< 100
3	C.O.D.	270	48	< 250
4	3 Day B.O.D. @ 27°C	88	8	< 100
5	Oil & Grease	BDL(MDL<1)	BDL(MDL<1)	< 10

1) **Activities undertaken during the month of May-2023.**

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Bach wash to sand and carbon filters.



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

402 Purushottam Plaza, Baner Road, Pune - 411045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT

Test Report No	2023/04/STPT/822	Date	19.04.2023
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
11.04.2023	12.04.2023	12.04.2023	19.04.2023

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.88
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 5)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	32
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	5
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 1)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Sanjay



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail: kleanlab@klean.org Website: www.klean.org

Ref. No. 2305/Vidyalankar/003

10th May, 2023

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT
AT YOUR WADALA CAMPUS FOR THE MONTH OF **APRIL-2023.**

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **April-2023.**


To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on 11/04/2023 and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	6.79	6.88	6.5 – 8.5
2	Suspended Solids	62	BDL(MDL<5)	< 100
3	C.O.D.	450	32	< 250
4	3 Day B.O.D. @ 27°C	152	5	< 100
5	Oil & Grease	BDL(MDL<1)	BDL(MDL<1)	< 10

1) **Activities undertaken during the month of April-2023.**

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Back wash to sand and carbon filters.



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

402 Purushottam Plaza, Baner Road, Pune - 411045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT			
Test Report No	2023/03/STPR/574	Date	18.03.2023
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Raw Sewage	Plastic Bottle	Lab	500 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
10.03.2023	11.03.2023	11.03.2023	18.03.2023

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.64
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	4
3	C.O.D.	APHA 5220 C 2017	mg/L	--	155
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	51
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

402 Purushottam Plaza, Baner Road, Pune - 411045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org



TEST REPORT					
Test Report No	2023/03/STPT/575	Date	18.03.2023		
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST				
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.				
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019				
WASTE WATER SAMPLE DETAILS					
Type/Location	Container	Collection by	Quantity		
Treated Sewage	Plastic Bottle	Lab	1000 ml		
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date		
10.03.2023	11.03.2023	11.03.2023	18.03.2023		
Sampling Procedure	As per KLRPL/QSP/22				
Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.52
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	BDL(MDL< 5)
3	C.O.D.	APHA 5220 C 2017	mg/L	--	13
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	2
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)
End of test report					
BDL: -Below Detectable level & MDL: -Method detection limit.					
This report cannot be reproduced in parts and pertains to the sample(s) as received.					
Hologram Mandatory.					
Page 1/1		Authorised by (Sanjay Mardikar G M)			



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Ref. No. 2304/Vidyalankar/001

10th April, 2023

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF MARCH-2023.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **March-2023**.


To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on 10/03/2023 and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	7.64	7.52	6.5 – 8.5
2	Suspended Solids	4	BDL(MDL<5)	< 100
3	C.O.D.	155	13	< 250
4	3 Day B.O.D. @ 27°C	51	2	< 100
5	Oil & Grease	BDL(MDL<5)	BDL(MDL<5)	< 10

1) Activities undertaken during the month of March-2023.

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Bach wash to sand and carbon filters.



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

TEST REPORT

Test Report No	2023/02/STPT/247	Date	17.02.2023
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai - 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Treated Sewage	Plastic Bottle	Lab	1000 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
09.02.2023	10.02.2023	10.02.2023	17.02.2023

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	6.78
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	8
3	C.O.D.	APHA 5220 C 2017	mg/L	--	69
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	10
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL< 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

TEST REPORT

Test Report No	2023/02/STPR/246	Date	17.02.2023
Name & Address of the Client	M/S. VIDYALANKAR DNYANAPEETH TRUST		
	Vidyalankar Education Complex, Vidyalankar College Marg, Sangam Nagar, Wadala (East) Mumbai – 400028.		
PO Details	Ref: E-17850 (Mumbai) Dated. 01 st July, 2019		

WASTE WATER SAMPLE DETAILS

Type/Location	Container	Collection by	Quantity
Raw Sewage	Plastic Bottle	Lab	500 ml
Sample collection Date	Sample receipt Date	Analysis start Date	Analysis complete Date
09.02.2023	10.02.2023	10.02.2023	17.02.2023

Sampling Procedure

As per KLRPL/QSP/22

Sr. No	Parameters	Method	Unit	Limit	Result
1	pH	APHA 4500- H+ B 2017	--	--	7.15
2	Suspended Solids	APHA 2540-D 2017	mg/L	--	74
3	C.O.D.	APHA 5220 C 2017	mg/L	--	428
4	3 Day B.O.D. @ 27°C	IS: 3025 (Part 44): RA 2014	mg/L	--	143
5	Oil & Grease	IS 3025 (Part 39) 2014	mg/L	--	BDL(MDL < 5)

End of test report

BDL: -Below Detectable level & MDL: -Method detection limit.

This report cannot be reproduced in parts and pertains to the sample(s) as received.

Hologram Mandatory.



Authorised by (Sanjay Mardikar G M)



KLEAN LABORATORIES AND RESEARCH (P) LTD.
CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.
vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.
402 Purushottam Plaza, Baner Road, Pune- 411 045.
Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

Ref. No. 2303/Vidyalankar/102

09th March, 2023

M/S. VIDYALANKAR DNYANPEETH TRUST
Vidyalankar Education Complex,
Vidyalankar College Marg, Sangam Nagar,
Wadala (East), Mumbai – 400028.

KIND ATTN: MR. SHAILESH MAPUSKAR (FACILITY MANAGER).

SUBJECT: REPORT FOR OPERATION AND MAINTENANCE OF SEWAGE TREATMENT PLANT AT YOUR WADALA CAMPUS FOR THE MONTH OF FEBRUARY-2023.

Dear Sir,

Following is the report on O&M of Sewage Treatment plant for **February-2023**.

To know the quality of raw and treated sewage samples, we had collected samples (Raw and treated) from the Sewage treatment plant on 09/02/2023 and the analysis report is as follows:

Sr. No.	Parameters	Raw Sewage	Treated Sewage	MPCB Standards
1	pH	7.15	6.78	6.5 – 8.5
2	Suspended Solids	74	8	< 100
3	C.O.D.	428	69	< 250
4	3 Day B.O.D. @ 27°C	143	10	< 100
5	Oil & Grease	BDL(MDL<5)	BDL(MDL<5)	< 10

1) **Activities undertaken during the month of February-2023.**

A) Daily Activities:

- Cleaning of plant area
- Lubrication and checking of mechanical equipment.
- Back wash to sand and carbon filters.



KLEAN LABORATORIES AND RESEARCH (P) LTD.

CIN : U73100MH2009PTC195098

An Environmental Laboratory approved by MoEFCC.

vide Gazette Notification of India Sr. No. 857 (E) Dated February 26, 2018 valid up to 2023.

402 Purushottam Plaza, Baner Road, Pune- 411 045.

Tel. 020-46781028 E-mail : kleanlab@klean.org Website: www.klean.org

B) Periodic Activities:

- Sludge removal and dewatering.
- Settling tank cleaning.
- Treated water tank cleaning.
- Water samples collection for analysis.

Our bill for operation of Sewage Treatment Plant of Rs. 16,158/- for the month of **February-2023** is enclosed for your certification and necessary payment.

Thanking You,

Yours Faithfully,

FOR KLEAN LABORATORIES AND RESEARCH PVT. LTD.



Authorized Signatory

- Encl.: 1) Analysis Reports of Raw and Treated sewage samples for the month **February-2023**
2) Bill for O & M of Sewage Treatment Plant for the month of **February-2023**